

## CLIENT CONFIDENTIAL

Client **Invacare Deutschland GmbH**

Test Item **M41**


Test **ISO 7176-19 Wheelchair Test**

Millbrook Report No. **11/0585**

Millbrook Project No. **CR0141-007-01**

Millbrook Test No. **S11772**

Author:



---

O. King  
Engineer

Approved:




---

A. Mulligan  
Engineer

Date:

17<sup>th</sup> August 2011



Millbrook Proving Ground Ltd  
Millbrook, Bedford, MK45 2JQ UK  
Tel: +44 (0)1525 404297  
Fax: +44 (0)1525 404226  
Email: [info@millbrook.co.uk](mailto:info@millbrook.co.uk)  
[www.millbrook.co.uk](http://www.millbrook.co.uk)

## Distribution

Organisation	Recipient	Format	Qty
INVACARE Deutschland GmbH Kleiststraße 49 D-32457 Porta Westfalica	D. Hoffmann	PDF	1
Millbrook Proving Ground Ltd Millbrook Bedford MK45 2JQ	Contract file	PDF	1

## Report Revision History

Rev.	Revision Description	Date	Author	Approver	Pages
0	Initial release	11 <sup>th</sup> August 2010	O. King	A. Mulligan	All

## Contents

Section	Page Nos.
Distribution.....	2
Report Revision History.....	2
Contents.....	3
Appendices.....	3
Test Facility and Date.....	3

## Appendices

Graphical Results	Appendix A
Pre and Post Test Photographs	Appendix B
Film Analysis	Appendix C
Test Results	Appendix D

## Test Facility and Date

The test, number S11772, was performed on 16<sup>th</sup> August 2011 at the HyGE Sled facility at Millbrook Proving Ground Ltd.

Address: Millbrook Proving Ground Ltd  
Millbrook  
Bedford  
MK45 2JQ  
England

Contact: Mr Andrew Mulligan  
Telephone: 01525 408 206  
Fax: 01525 408 203  
Email: [Andrew.Mulligan@millbrook.co.uk](mailto:Andrew.Mulligan@millbrook.co.uk)



# Test Report



## Test Results

ISO/NP 7176/19  
16<sup>th</sup> August 2011

### Section 5.2 - Dynamic Performance Requirements

Test No: Client: Wheelchair: Occupant:	S11772 Invacare Deutschland GmbH M41 50 <sup>th</sup> ile (75 kg)	RESULTS
<b>5.2.1 During the Test</b>		
a) Horizontal ATD and wheelchair excursion limits as per limits shown in Table 3:-		
Was the horizontal movement of the test wheelchair P- Point ( $X_{wc}$ ) less than 200 mm ( $\pm 5$ mm)		PASS 128 mm
Was the horizontal movement of the dummy knee ( $X_{knee}$ ) less than 375 mm ( $\pm 5$ mm)		PASS 360 mm
Was the horizontal movement of the dummy head ( $X_{head}$ ) less than 650 mm ( $\pm 5$ mm)		PASS 537 mm
b) Was the ratio $X_{knee} / X_{wc} > 1.1:1$		PASS 2.81 : 1
c) Not Conducted		
Did the batteries of powered wheelchairs, or their surrogate parts:-		
i) move outside of the wheelchair footprint		PASS
ii) move into the wheelchair user's space		PASS
<b>5.2.1 Post Test</b>		
a) Did the wheelchair remain upright on the test platform Did the ATD remain in a seated posture in the test wheelchair with a torso angle less than 45°		PASS
b) Did the wheelchair securement points show visible signs of material failure		PASS
c) Did any components of a mass greater than 100g become detached from the wheelchair		PASS
d) Did any occupant contactable components fragment or separate with an edge of less than 2mm		PASS
e) Did any primary load carrying components of the wheelchair show any visible signs of failure		PASS
f) Did any 'tilt in space' locking mechanisms show signs of failure		PASS
g) Was the ATD released from the wheelchair without the use of tools		PASS
h) Was the wheelchair released from the restraint system without the use of tools		PASS
i) Was the average decrease of H-Point height relative to the wheelchair platform less than 20% of the pre-test height.		PASS
Has the wheelchair satisfied the Dynamic Test requirements of ISO/FDIS 7176/19 of 7th July 2008		<b>PASS</b>