

# CONFIDENTIAL

INVACARE REA AB

ISO 7176/19  
WHEELCHAIR DYNAMIC CRASH  
HYGE SLED TEST

WHEELER – TRANSPORT COMFORT

TEST DATE: 18<sup>TH</sup> JUNE 2001  
MILLBROOK TEST No.: S7461  
MILLBROOK REPORT No.: MBK 01/0408

Test No.: S7461



## DISTRIBUTION

Invacare REA AB.:  
Millbrook P.G.:

Goran Nilsson  
Safety Test Laboratory  
Contract File

(1 Copy)  
(Originals)  
(B/W Photocopies)

## TEST DESCRIPTION

Test No.: S7461  
Test Date: 18<sup>th</sup> June 2001  
Test Type: ISO 7176/19 Wheelchair Dynamic Crash Test

Occupant: HIII 5<sup>th</sup> Percentile (53 kg).


Wheelchair Type: Wheeler – Transport Comfort  
(Less Foot Straps)

Restraint System: Unwin  
Occupant: WWR/SW/ATS/R  
Wheelchair: WWR/3H/ATF/FA/WH

## CONTENTS

Graphical Results	Appendix A
Transducer Calibration Report	
Still Photographs	Appendix B
Film Analysis	Appendix C
Test Results	Appendix D

Prepared by:

  
B. Appleyard – Senior Engineer

Date:

16 July 2001

Approved by:

  
P. Glyn-Davies - Manager


Date:

16 JULY '01

PRELIMINARY DATA



SLED ACCELERATION



Customer : Invacare  
: (Sweden)

Test Number: S7461  
Test Date : 18 June 2001

Test Type : ISO/FDIS 7176/19  
: Dynamic Test

Dummy Type : Hybrid III 50ile

Wheelchair : Wheeler  
: Transport Comfort  
: No Shoe Straps

Restraints : Unwin

Test Eng. : G. Nilsson  
Millbrook : B. Appleyard


Sled Pulse Criteria - Acceptable

Filter : CRC 60 (SAE J211)  
CAC : 200.67 [g]  
Sensor ID : ZU41  
Max Value : 1.39 g [113.5 msec]  
Min Value : -22.89 g [ 53.7 msec]  
Plot Date : 18.06.2001 at 15:51:12

# PRELIMINARY DATA



## SLED ACCELERATION



## CRASH TEST LABORATORIES

Customer : Invacare  
: (Sweden)  
Test Number: S7461  
Test Date : 18 June 2001  
Test Type : ISO/FDIS 7176/19  
: Dynamic Test  
Dummy Type : Hybrid III 5&ile  
Wheelchair : Wheeler  
: Transport Comfort  
: No Shoe Straps  
Restraints : Dawin  
Test Eng. : G. Nilsson  
Millbrook : B. Appleyard

Filter : CFC 180 (SAE J211)  
CAC : 200.67 (g)  
Sensor ID : 2341

### Acceleration

Max Value : 1.66 g [112.5 msec]  
Min Value : -22.99 g [ 54.4 msec]

### Velocity


Max Value : 14.04 m/s [110.0 msec]  
Min Value : 0.00 m/s [ 0.1 msec]

### Displacement

Max Value : 12.03 m [1016.9 msec]  
Min Value : 0.00 m [ 0.1 msec]  
Plot Date : 18.06.2001 at 15:51:19

— Acceleration — Velocity — Displacement

# ECE R44 Fwd





## Test Results

ISO/FDIS 7176/19  
(07/NOV/2000)

### Section 5 - Dynamic Performance Requirements

WHEELCHAIR	Wheeler – Transport Comfort (Less Foot Straps)	RESULTS
5.2.1	<b>During the Test</b>	
5.3.1	a). Horizontal ATD and wheelchair excursion limits as per limits shown in Table 3:-	
	Was the horizontal movement of the test wheelchair P- Point (X wc) less than 200 mm. ( $\pm 5$ mm)	PASS 81mm
	Was the horizontal movement of the dummy knee (X knee) less than 375 mm. ( $\pm 5$ mm)	PASS 168mm
	Was the horizontal movement of the dummy head (X head) less than 650 mm. ( $\pm 5$ mm)	PASS 290mm
	b). Was the ratio X knee/X wc >1.1	PASS 2.1:1
	c). Not Measured	
	d). Did the batteries of powered wheelchairs, or their surrogate parts:-	N/A
	i). move outside of the wheelchair footprint	N/A
	ii). move into the wheelchair user's space	N/A
5.2.2	<b>Post Test</b>	
5.3.2	a). Did the wheelchair remain upright on the test platform Did the ATD remain in a seated posture in the test wheelchair with a torso angle less than 45°	PASS PASS
	b). Did the wheelchair securement points show visible signs of material failure	PASS
	c). Did any components of a mass greater than 100g become detached from the wheelchair	PASS
	d). Did any occupant contactable components fragment or separate with an edge of less than 2mm	PASS
	e). Did any primary load carrying components of the wheelchair show any visible signs of failure	PASS
	f). Did any 'tilt in space' locking mechanisms show signs of failure	PASS
	g). Was the ATD released without the use of tools	PASS
	f). Was the wheelchair released from the restraint system without the use of tools	PASS
	h). Was the average decrease of H-Point height relative to the wheelchair platform less than 20% of the pre-test height.	PASS 5%
	Has the wheelchair satisfied the Dynamic Test requirements of ISO/FDIS 7176/19 of 07/November/2000	PASS

Invacare REA AB S7461




## TRANSDUCER CALIBRATION REPORT

Chan No.	Channel Description	Transducer Make	Transducer Model	Trans No.	CFC	CAC	Calibration Date	In Cal
3	SLED ACCELERATION	ENDEVCO	2262C-200	ZU41	1000	201	13-Jul-2000	Yes




Front view of wheelchair and occupant, pre-test



Front 3/4 view of wheelchair and occupant, pre-test





RH view of wheelchair and occupant, pre-test



Rear view of wheelchair and occupant, pre-test



View of wheelchair front tie-downs, pre-test



View of wheelchair rear tie-downs, pre-test



View of occupant upper torso anchorage, pre-test



Front view of wheelchair and occupant, post-test



Front 3/4 view of wheelchair and occupant, post-test



RH view of wheelchair and occupant, post-test



Rear 3/4 view of wheelchair and occupant, post-test



Rear view of wheelchair and occupant, post-test



View of wheelchair front tie-downs, post-test



View of wheelchair rear tie-downs, post-test



View of occupant upper torso anchorage, post-test